

Ministry of the  
Environment, Conservation  
and Parks  
Drinking Water and  
Environmental Compliance  
Division  
West Central Region  
Guelph District Office

Ministère de l'Environnement de  
la Protection de la nature et des  
Parcs  
Division de la conformité en  
d'eau potable et d'environnement  
Direction régionale du Centre-  
Ouest  
Bureau de district de Guelph



1 Stone Road West  
4<sup>th</sup> Floor  
Guelph, Ontario N1G 4Y2  
Tel.: 519 826-4255  
Fax: 519 826-4286

1, chemin Stone ouest  
4 e étage  
Guelph (Ontario) N1G 4Y2  
Tél.: 519 826-4255  
Télé.: 519 826-4286

March 9, 2023

\*\*Sent via email\*\*

Township of Mulmur  
758070 2<sup>nd</sup> Line East  
Terra Nova, Ontario  
L0M 1M0

Attention: Mr. John Willmetts  
Director of Public Works

Re: Mansfield Drinking Water System Inspection Report  
Waterworks #260063661, Our File: SI DU MU AI 540

On January 23, 2023, the Mansfield Drinking Water System was inspected by the Ministry of the Environment, Conservation and Parks. The inspection followed the detailed inspection protocol to assess compliance with the Safe Drinking Water Act legislation. The report is based on conditions encountered at the time of inspection, and subsequent follow-up. Please find attached a copy of the Inspection Report #1-106839529.

Any items under the heading “Non-Compliance with Regulatory Requirements and Actions Required” are linked to incidents of non-compliance with regulatory requirements contained within the Act, a regulation, or site-specific approvals, licenses, permits, orders or instructions.

In order to measure individual inspection results, the Ministry has established an inspection compliance risk framework based on the principles of the Inspection, Investigation & Enforcement (II&E) Secretariat and advice of internal/external risk experts. The Inspection Summary Rating Record (IRR), included as part of the inspection report, provides the Ministry, the system owner and the local Public Health Units with a summarized quantitative measure of the drinking water system’s annual inspection and regulated water quality testing performance. IRR ratings are published (for the previous inspection year) in the Ministry’s Chief Drinking Water Inspectors’ Annual Report. If you have any questions or concerns regarding the rating, please contact Lisa Williamson, Water Compliance Supervisor, at 226-979-8468.

Please note that due to a change in IT systems, the IRR cannot be generated at the same time as the inspection report. The IRR will be sent separately and prior to any release (typically within 1-2 months of the completion of the inspection).

Section 19 of the Safe Drinking Water Act (Standard of Care) creates a number of obligations for individuals who exercise decision-making authority over municipal drinking water systems. Please be aware that the Ministry has encouraged such individuals, particularly municipal councilors, to take steps to be better informed about the drinking water systems over which they have decision-making authority. These steps could include asking for a copy of this inspection report and a review of its findings. Further information about Section 19 can be found in “Taking Care of Your Drinking Water: A guide for members of municipal council” found on the Ministry of the Environment, Conservation and Parks website at [www.ontario.ca](http://www.ontario.ca).

If you wish to discuss the results of the inspection in more detail, please feel free to contact me at (519) 837-7457.

Yours truly,

Signature: (Provincial Officer)



Carola Serwotka  
Provincial Officer  
Drinking Water and Environmental Compliance Division  
Guelph District Office  
West Central Region

c.c.

Joe Miedema, Dufferin Water Co. Ltd. (email)  
Phil Wong, Manager, Health Protection Division, Wellington, Dufferin, Guelph Health Unit (email)  
Ryan Post, Nottawasaga Valley Conservation Authority (email)  
Guelph District Office File: SI DU MU AI 540, Mansfield DWS  
Electronic Binder



MANSFIELD DRINKING WATER SYSTEM  
936541 AIRPORT RD, MULMUR, ON, L0M 1M0  
**Inspection Report**

System Number: 260063661  
Entity: DUFFERIN WATER CO LTD  
TOWNSHIP OF MULMUR  
Inspection Start Date: 01/23/2023  
Inspection End Date: 03/09/2023  
Inspected By: Carola Serwotka  
Badge #: 808

Signature: (Provincial Officer)





### **NON-COMPLIANCE/NON-CONFORMANCE ITEMS**

This should not be construed as a confirmation of full compliance with all potential applicable legal requirement and BMPs. These inspection findings are limited to the components and/or activities that were assessed, and the legislative framework(s) that were applied. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

If you have any questions related to this inspection, please contact the signed Provincial Officer.

## INSPECTION DETAILS

This section includes all questions that were assessed during the inspection.

**Ministry Program:** DRINKING WATER | **Regulated Activity:**

Question ID	MRDW1001001	Question Type	Information
<b>Question:</b>			
What was the scope of this inspection?			
Legislative Requirement	Not Applicable		
<b>Observation</b>			
<p>The primary focus of this inspection is to confirm compliance with Ministry of the Environment, Conservation and Parks (MECP) legislation as well as evaluating conformance with ministry drinking water policies and guidelines during the inspection period. The ministry utilizes a comprehensive, multi-barrier approach in the inspection of water systems that focuses on the source, treatment, and distribution components as well as management practices.</p> <p>This drinking water system is subject to the legislative requirements of the Safe Drinking Water Act, 2002 (SDWA) and regulations made therein, including Ontario Regulation 170/03, "Drinking Water Systems" (O. Reg. 170/03). This inspection has been conducted pursuant to Section 81 of the SDWA.</p> <p>This inspection report does not suggest that all applicable legislation and regulations were evaluated. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements. The Mansfield Drinking Water System (DWS #260063661) is a large drinking water system with approximately 153 service connections. It is owned by the Township of Mulmur in Dufferin Township and operated by Dufferin Water Co. Ltd.</p> <p>The Mansfield Drinking Water System is a Class 2 Water Distribution and Supply Subsystem (WDSS) with certificate #2885, and was issued on July 12, 2006. Mansfield is located 90km north-east of Guelph, Ontario.</p> <p>Municipal Drinking Water Licence Number 248- 101 (Issue Number 5) and Drinking Water Works Permit Number 248-201 (Issue Number 5) were both issued on November 27, 2020. Permit To Take Water (PTTW) 6581-BT4KK7 was issued on September 4, 2020 with an expiry of May 31, 2024.</p> <p>The announced, focussed inspection began on January 23, 2023 in Mansfield with the attendance of the ORO. The inspection period for this inspection was December 1, 2021 to January 23, 2023.</p>			

<b>Question ID</b>	MRDW1000001	<b>Question Type</b>	Information
<b>Question:</b> Does this drinking water system provide primary disinfection?			
<b>Legislative Requirement</b>	Not Applicable		
<b>Observation</b>			
This Drinking Water System provides for both primary and secondary disinfection and distribution of water.			

<b>Question ID</b>	MRDW1018001	<b>Question Type</b>	Legislative
<b>Question:</b> Has the owner ensured that all equipment is installed in accordance with Schedule A and Schedule C of the Drinking Water Works Permit?			
<b>Legislative Requirement</b>	SDWA   31   (1);		
<b>Observation</b>			
The owner had ensured that all equipment was installed in accordance with Schedule A and Schedule C of the Drinking Water Works Permit.			

<b>Question ID</b>	MRDW1114001	<b>Question Type</b>	Legislative
<b>Question:</b> Does the owner have evidence that, when required, all legal owners associated with the DWS were notified of the requirements of the Licence & Permit?			
<b>Legislative Requirement</b>	SDWA   31   (1);		
<b>Observation</b>			
The owner had evidence that required notifications to all legal owners associated with the Drinking Water System had been made during the inspection period.			

<b>Question ID</b>	MRDW1025001	<b>Question Type</b>	Legislative
<b>Question:</b> Were all parts of the drinking water system that came in contact with drinking water (added, modified, replaced or extended) disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit?			
<b>Legislative Requirement</b>	SDWA   31   (1);		

<b>Observation</b>
All parts of the drinking water system were disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit.

<b>Question ID</b>	MRDW1024001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Do records confirm that the water treatment equipment which provides chlorination or chloramination for secondary disinfection purposes was operated as required?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   1-2   (2);		
<b>Observation</b>			
Records confirmed that the water treatment equipment which provides chlorination or chloramination for secondary disinfection purposes was operated so that at all times and all locations in the distribution system the chlorine residual was never less than 0.05 mg/l free or 0.25 mg/l combined.			

<b>Question ID</b>	MRDW1038001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Is continuous monitoring equipment that is being utilized to fulfill O. Reg. 170/03 requirements performing tests for the parameters with at least the minimum frequency specified in the Table in Schedule 6 of O. Reg. 170/03 and recording data with the prescribed format?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   6-5   (1)1-4;		
<b>Observation</b>			
Continuous monitoring equipment that was being utilized to fulfill O. Reg. 170/03 requirements was performing tests for the parameters with at least the minimum frequency specified in the Table in Schedule 6 of O. Reg. 170/03 and recording data with the prescribed format. Continuous data provided during the inspection was every 4 minutes.			

<b>Question ID</b>	MRDW1035001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Are operators examining continuous monitoring test results and are they examining the results within 72 hours of the test?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   6-5   (1)1-4; SDWA   O. Reg. 170/03   6-5   (1)5-10;		



<b>Observation</b>
Operators were examining continuous monitoring test results and they were examining the results within 72 hours of the test. Every other day, the continuous data is downloaded from the on-site computer and verified for any unusual events.

<b>Question ID</b>	MRDW1037001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Are all continuous monitoring equipment utilized for sampling and testing required by O. Reg. 170/03, or MDWL or DWWP or order, equipped with alarms or shut-off mechanisms that satisfy the standards described in Schedule 6?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   6-5   (1)1-4; SDWA   O. Reg. 170/03   6-5   (1)5-10; SDWA   O. Reg. 170/03   6-5   (1.1);		
<b>Observation</b>			
All continuous monitoring equipment utilized for sampling and testing required by O. Reg. 170/03, or Municipal Drinking Water Licence or Drinking Water Works Permit or order, were equipped with alarms or shut-off mechanisms that satisfy the standards described in Schedule 6. During the inspection, the low chlorine alarm was tested and the drinking water system shut-down as required.			

<b>Question ID</b>	MRDW1040000	<b>Question Type</b>	Legislative
<b>Question:</b>			
Are all continuous analysers calibrated, maintained, and operated, in accordance with the manufacturer's instructions or the regulation?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   6-5   (1)1-4; SDWA   O. Reg. 170/03   6-5   (1)5-10;		
<b>Observation</b>			
All continuous analysers were calibrated, maintained, and operated, in accordance with the manufacturer's instructions or the regulation. Continuous analyzers are checked daily and calibrated to the hand held portable analyzers as required.			

<b>Question ID</b>	MRDW1108001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Where continuous monitoring equipment used for the monitoring of free chlorine residual, total chlorine residual, combined chlorine residual or turbidity, required by O. Reg. 170/03, an Order, MDWL, or DWWP issued under Part V, SDWA, has triggered an alarm or an automatic shut-off, did a qualified person respond in a timely manner and take appropriate			

actions?	
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   6-5   (1)1-4; SDWA   O. Reg. 170/03   6-5   (1)5-10; SDWA   O. Reg. 170/03   6-5   (1.1);
<b>Observation</b>	
Where required continuous monitoring equipment used for the monitoring of chlorine residual and/or turbidity triggered an alarm or an automatic shut-off, a qualified person responded in a timely manner and took appropriate actions.	

<b>Question ID</b>	MRDW1033001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Is the secondary disinfectant residual measured as required for the large municipal residential distribution system?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   7-2   (3); SDWA   O. Reg. 170/03   7-2   (4);		
<b>Observation</b>			
The secondary disinfectant residual was measured as required for the large municipal residential distribution system. Distribution free chlorine is measured continually in the Municipal Office and checked daily with a handheld portable chlorine analyzer.			

<b>Question ID</b>	MRDW1099001	<b>Question Type</b>	Information
<b>Question:</b>			
Do records show that all water sample results taken during the inspection review period did not exceed the values of tables 1, 2 and 3 of the Ontario Drinking Water Quality Standards (O. Reg. 169/03)?			
<b>Legislative Requirement</b>	Not Applicable		
<b>Observation</b>			
Records showed that all water sample results taken during the inspection review period did not exceed the values of tables 1, 2 and 3 of the Ontario Drinking Water Quality Standards (O. Reg. 169/03).			

<b>Question ID</b>	MRDW1081001	<b>Question Type</b>	Legislative
<b>Question:</b>			
For LMR systems, are all microbiological water quality monitoring requirements for distribution samples being met?			

<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   10-2   (1); SDWA   O. Reg. 170/03   10-2   (2); SDWA   O. Reg. 170/03   10-2   (3);
<b>Observation</b>	
All microbiological water quality monitoring requirements prescribed by legislation for distribution samples in a large municipal residential system were being met. Distribution samples are taken 2 to 3 times weekly as required.	

<b>Question ID</b>	MRDW1096001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Do records confirm that chlorine residual tests are being conducted at the same time and at the same location that microbiological samples are obtained?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   6-3   (1);		
<b>Observation</b>			
Records confirmed that chlorine residual tests were being conducted at the same time and at the same location that microbiological samples were obtained.			

<b>Question ID</b>	MRDW1086001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Are all haloacetic acid water quality monitoring requirements prescribed by legislation conducted within the required frequency and at the required location?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-6.1   (1); SDWA   O. Reg. 170/03   13-6.1   (2); SDWA   O. Reg. 170/03   13-6.1   (3); SDWA   O. Reg. 170/03   13-6.1   (4); SDWA   O. Reg. 170/03   13-6.1   (5); SDWA   O. Reg. 170/03   13-6.1   (6);		
<b>Observation</b>			
All haloacetic acid water quality monitoring requirements prescribed by legislation were conducted within the required frequency and at the required location. HAA sampling and testing occurred quarterly as required.			

<b>Question ID</b>	MRDW1087001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Have all trihalomethane water quality monitoring requirements prescribed by legislation been conducted within the required frequency and at the required location?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-6   (1); SDWA   O. Reg. 170/03   13-6   (2); SDWA   O. Reg. 170/03   13-6   (3); SDWA   O.		

	Reg. 170/03   13-6   (4); SDWA   O. Reg. 170/03   13-6   (5); SDWA   O. Reg. 170/03   13-6   (6);
<b>Observation</b>	
All trihalomethane water quality monitoring requirements prescribed by legislation were conducted within the required frequency and at the required location. THM sampling and testing occurred quarterly as required.	

<b>Question ID</b>	MRDW1094001	<b>Question Type</b>	Legislative
<b>Question:</b> Are all water quality monitoring requirements imposed by the MDWL and DWWP being met?			
<b>Legislative Requirement</b>	SDWA   31   (1);		
<b>Observation</b>			
All water quality monitoring requirements imposed by the MDWL or DWWP issued under Part V of the SDWA were being met.			

<b>Question ID</b>	MRDW1113000	<b>Question Type</b>	Legislative
<b>Question:</b> Have all changes to the system registration information been provided to the Ministry within ten (10) days of the change?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   10.1   (3);		
<b>Observation</b>			
All changes to the system registration information were provided within ten (10) days of the change.			

<b>Question ID</b>	MRDW1059000	<b>Question Type</b>	Legislative
<b>Question:</b> Do the operations and maintenance manuals contain plans, drawings and process descriptions sufficient for the safe and efficient operation of the system?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 128/04   28;		
<b>Observation</b>			
The operations and maintenance manuals contained plans, drawings and process descriptions sufficient for the safe and efficient operation of the system.			

--

<b>Question ID</b>	MRDW1060000	<b>Question Type</b>	Legislative
<b>Question:</b> Do the operations and maintenance manuals meet the requirements of the DWWP and MDWL issued under Part V of the SDWA?			
<b>Legislative Requirement</b>	SDWA   31   (1);		
<b>Observation</b> The operations and maintenance manuals met the requirements of the Drinking Water Works Permit and Municipal Drinking Water Licence issued under Part V of the SDWA.			

<b>Question ID</b>	MRDW1061001	<b>Question Type</b>	Legislative
<b>Question:</b> Are logbooks properly maintained and contain the required information?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 128/04   27   (1); SDWA   O. Reg. 128/04   27   (2); SDWA   O. Reg. 128/04   27   (3); SDWA   O. Reg. 128/04   27   (4); SDWA   O. Reg. 128/04   27   (5); SDWA   O. Reg. 128/04   27   (6); SDWA   O. Reg. 128/04   27   (7);		
<b>Observation</b> Logbooks were properly maintained and contained the required information. Logsheets have daily entries for each month of the year.			

<b>Question ID</b>	MRDW1062001	<b>Question Type</b>	Legislative
<b>Question:</b> Do records or other record keeping mechanisms confirm that operational testing not performed by continuous monitoring equipment is being done by a certified operator, water quality analyst, or person who meets the requirements of O. Reg. 170/03 7-5?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   7-5;		
<b>Observation</b> Records or other record keeping mechanisms confirmed that operational testing not performed by continuous monitoring equipment was being done by a certified operator, water quality analyst, or person who suffices the requirements of O. Reg. 170/03 7-5.			

<b>Question ID</b>	MRDW1071000	<b>Question Type</b>	BMP
--------------------	-------------	----------------------	-----

<b>Question:</b> Has the owner provided security measures to protect components of the drinking water system?	
<b>Legislative Requirement</b>	Not Applicable
<b>Observation</b> The owner had provided security measures to protect components of the drinking water system. The water treatment plant is locked and secure and is surrounded by a fence.	

<b>Question ID</b>	MRDW1073001	<b>Question Type</b>	Legislative
<b>Question:</b> Has the overall responsible operator been designated for all subsystems which comprise the drinking water system?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 128/04   23   (1);		
<b>Observation</b> The overall responsible operator had been designated for each subsystem.			

<b>Question ID</b>	MRDW1074001	<b>Question Type</b>	Legislative
<b>Question:</b> Have operators-in-charge been designated for all subsystems for which comprise the drinking water system?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 128/04   25   (1);		
<b>Observation</b> Operators-in-charge had been designated for all subsystems which comprise the drinking water system.			

<b>Question ID</b>	MRDW1075001	<b>Question Type</b>	Legislative
<b>Question:</b> Do all operators possess the required certification?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 128/04   22;		
<b>Observation</b> All operators possessed the required certification.			

--

<b>Question ID</b>	MRDW1076001	<b>Question Type</b>	Legislative
<b>Question:</b> Do only certified operators make adjustments to the treatment equipment?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   1-2   (2);		
<b>Observation</b> Only certified operators made adjustments to the treatment equipment.			

<b>Question ID</b>	MRDW1007001	<b>Question Type</b>	Legislative
<b>Question:</b> Is the owner maintaining the production well(s) in a manner sufficient to prevent entry into the well of surface water and other foreign materials?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   1-2   (1);		
<b>Observation</b> The owner was maintaining the production well(s) in a manner sufficient to prevent entry into the well of surface water and other foreign materials.			

<b>Question ID</b>	MRDW1009001	<b>Question Type</b>	Legislative
<b>Question:</b> Are measures in place to protect the groundwater and/or GUDI source in accordance with any MDWL and DWWP issued under Part V of the SDWA?			
<b>Legislative Requirement</b>	SDWA   31   (1);		
<b>Observation</b> Measures were in place to protect the groundwater and/or GUDI source in accordance with the Municipal Drinking Water Licence and Drinking Water Works Permit issued under Part V of the SDWA. The wells are inspected twice a year to ensure the wells are secure.			

<b>Question ID</b>	MRDW1014001	<b>Question Type</b>	Legislative
<b>Question:</b> Is there sufficient monitoring of flow as required by the MDWL or DWWP issued under Part V of the SDWA?			

<b>Legislative Requirement</b>	SDWA   31   (1);
<b>Observation</b>	
There was sufficient monitoring of flow as required by the Municipal Drinking Water Licence or Drinking Water Works Permit issued under Part V of the SDWA.	

<b>Question ID</b>	MRDW1016001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Is the owner in compliance with the conditions associated with maximum flow rate or the rated capacity conditions in the MDWL issued under Part V of the SDWA?			
<b>Legislative Requirement</b>	SDWA   31   (1);		
<b>Observation</b>			
The owner was in compliance with the conditions associated with maximum flow rate or the rated capacity conditions in the Municipal Drinking Water Licence issued under Part V of the SDWA. The annual average vs maximum flowrates as a percent of the approved rated capacity are summarized as follows:			
	2021	2022	
Well 1	23%/64%	25%/76%	
Well 2	9%/25%	2.7%/13%	
Well 3	0	0	
To Distribution	10% /28%	9.7%/28%	

<b>Question ID</b>	MRDW1023001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Do records indicate that the treatment equipment was operated in a manner that achieved the design capabilities required under Ontario Regulation 170/03 or a DWWP and/or MDWL issued under Part V of the SDWA at all times that water was being supplied to consumers?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   1-2   (2);		
<b>Observation</b>			
Records indicated that the treatment equipment was operated in a manner that achieved the design capabilities required under O. Reg. 170/03 or a Drinking Water Works Permit and/or Municipal Drinking Water Licence issued under Part V of the SDWA at all times that water was being supplied to consumers.			



<b>Question ID</b>	MRDW1030000	<b>Question Type</b>	Legislative
<b>Question:</b> Is primary disinfection chlorine monitoring being conducted at a location approved by MDWL and/or DWWP issued under Part V of the SDWA, or at/near a location where the intended CT has just been achieved?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   7-2   (1); SDWA   O. Reg. 170/03   7-2   (2);		
<b>Observation</b> Primary disinfection chlorine monitoring was conducted at a location approved by Municipal Drinking Water Licence and/or Drinking Water Works Permit issued under Part V of the SDWA, or at/near a location where the intended CT has just been achieved.			

<b>Question ID</b>	MRDW1083001	<b>Question Type</b>	Legislative
<b>Question:</b> For LMR systems, are all microbiological water quality monitoring requirements for treated samples being met?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   10-3;		
<b>Observation</b> All microbiological water quality monitoring requirements prescribed by legislation for treated samples were being met. Treated microbiological samples are tested weekly at the water treatment plant.			

<b>Question ID</b>	MRDW1084001	<b>Question Type</b>	Legislative
<b>Question:</b> Are all inorganic water quality monitoring requirements prescribed by legislation conducted within the required frequency?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-2;		
<b>Observation</b> All inorganic water quality monitoring requirements prescribed by legislation were conducted within the required frequency. The last set of inorganic samples were tested on June 29, 2021.			

<b>Question ID</b>	MRDW1088000	<b>Question Type</b>	Legislative
<b>Question:</b>			

Are all nitrate/nitrite water quality monitoring requirements prescribed by legislation conducted within the required frequency for the DWS?	
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-7;
<b>Observation</b>	
All nitrate/nitrite water quality monitoring requirements prescribed by legislation were conducted within the required frequency for the DWS. Nitrate/nitrite samples are taken and tested quarterly.	

<b>Question ID</b>	MRDW1089000	<b>Question Type</b>	Legislative
<b>Question:</b>			
Are all sodium water quality monitoring requirements prescribed by legislation conducted within the required frequency?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-8;		
<b>Observation</b>			
All sodium water quality monitoring requirements prescribed by legislation were conducted within the required frequency. Sodium sampling and testing occurs every 60 months with the last sample taken on June 29, 2021.			

<b>Question ID</b>	MRDW1090000	<b>Question Type</b>	Legislative
<b>Question:</b>			
Where fluoridation is not practiced, are all fluoride water quality monitoring requirements prescribed by legislation conducted within the required frequency?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-9;		
<b>Observation</b>			
All fluoride water quality monitoring requirements prescribed by legislation were conducted within the required frequency. Fluoride sampling and testing occurs every 60 months with the last sample taken on May 23, 2018.			

<b>Question ID</b>	MRDW1085001	<b>Question Type</b>	Legislative
<b>Question:</b>			
Are all organic water quality monitoring requirements prescribed by legislation conducted within the required frequency?			
<b>Legislative Requirement</b>	SDWA   O. Reg. 170/03   13-4   (1); SDWA   O. Reg. 170/03   13-4   (2); SDWA   O. Reg. 170/03   13-4   (3);		

**Observation**

All organic water quality monitoring requirements prescribed by legislation were conducted within the required frequency. The last set of organic samples were tested on June 29, 2021.